

**Part III Form 2
Section 11. ANNUAL REPORT.**

Drinking-Water System Number:	260080106
Drinking-Water System Name:	Strathroy Water Works
Drinking-Water System Owner:	Municipality of Strathroy-Caradoc
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2007 to December 31, 2007

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Municipality of Strathroy-Caradoc 351 Frances Street Strathroy, Ontario N7G 2L7 </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

List Drinking-Water Systems, which receive all of their drinking water from your system:

Adelaide-Metcalf Small Municipal Non-Residential System

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [X] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

On December 23, 2005, Strathroy connected to the Lake Huron Water Supply System and all wells were shut down in 2006.

The distribution system consists of the Head Street water tower (capacity 1,900 m³), the Second Street reservoir (capacity 11,250 m³) and 95 kms of water mains serving the local street network.

The reservoir/pump station has the following rated pump capacities:

Pump #1	80 L/s
Pump #2	139 L/s
Pump #3	212 L/s
Pump #4	39 L/s
Pump #5	39 L/s

The water distribution system services a population of approximately 13,500 in the Municipality of Strathroy-Caradoc and Township of Adelaide-Metcalf.

Water Quality information pertaining to the new water supply (Lake Huron Primary Water System) may be obtained from the following web site and viewing the report tab.
www.watersupply.london.ca

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Describe

The existing 100 mm cast iron watermain (1940) on Carrie Street was replaced with 200 mm PVC. The existing 350 mm watermain on Canaan Street was replaced with PVC pipe in the course of conducting a site remediation. In addition, the 100 mm watermain on Canaan within the contract limits of the remediation was abandoned. The Adair Boulevard (400 mm PVC) and Wright Street (300 mm PVC) watermains were installed completing the loop of the Molnar Industrial Park. On Milliner Street, the sanitary sewer was replaced in 2007. In the course of this work, an old watermain was found still in service. The existing services were brought over to the existing Milliner 150 mm Watermain and the old line abandoned.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
07/07/10	Carrie St. Sample Stn Total Coliform	10	Count/ 100ml	Resample	07/07/13
07/07/10	Adair Blvd. Sample Stn Total Coliform	1	Count/ 100ml	Resample	07/07/13

Microbiological testing done under section 8-2 during this reporting period

	Number of Samples	Range of E.Coli Or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of Samples Background Colony Counts	Range of Background Colony Counts (#-#)
Raw	N/A				
Treated	N/A				
Distribution	304	0-0	0-10	304	0-2000

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity	N/A	
Chlorine	N/A	
Chlorine Residual Distribution System	8760	0-1.71
Fluoride (If the DWS provides fluoridation)	N/A	

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

End of Distribution Sample (Albert Street West Sample Station)

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead	Nov 13/07	0.32	ug/L	No
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				

Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Linadane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: show latest annual average)	Feb 13/07	16	ug/L	No
	May 8/07	24	ug/L	No
	Aug 14/07	27	ug/L	No
	Nov 13/07	20	ug/L	No
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				

2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Lead	6.22	ug/L	May 31/2007

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)