

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220002173
Drinking-Water System Name:	Strathroy Water Works
Drinking-Water System Owner:	Township of Strathroy-Caradoc
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2005 to December 31, 2005

<u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u> Does your Drinking-Water System serve more than 10,000 people? Yes [X] No [] Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [] Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection. Township of Strathroy-Caradoc 351 Frances Street Strathroy, Ontario N7G 2L7	<u>Complete for all other Categories.</u> Number of Designated Facilities served: Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [] Number of Interested Authorities you report to: Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []
--	---

List Drinking-Water Systems, which receive all of their drinking water from your system:

None

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [X]

Indicate how you notified system users that your annual report is available, and is free of charge.

[X] Public access/notice via the web

[] Public access/notice via Government Office

[X] Public access/notice via a newspaper

☒ Public access/notice via Public Request

☐ Public access/notice via a Public Library

☐ Public access/notice via other method _____

Describe your Drinking-Water System

The Strathroy water works is supplied with water from thirteen water wells (Wells 1, 2, 3, 4, 5, 6, 8, 9, 11B, 11D, 13, 14, and 15) situated in seven well fields located throughout the Community of Strathroy and to the south of Strathroy. The wells extract groundwater from the upper sand aquifer throughout the Strathroy area. The distribution system consists of the Head Street water tower, the Second Street reservoir and water mains serving the local street network. A population of approximately 13,500 is served by the distribution system.

Prior to entering the distribution system the water is disinfected at each well by chlorination. Disinfection by chlorination also occurs at the Second Street reservoir. At wells 11B, 11D, 14 and 15, naturally occurring iron is present in the groundwater and stabilization of iron is achieved through the use of small, potable amounts of sodium silicate solution. The treatment reduces the potential for iron to stain plumbing fixtures and clothing during laundering. Iron is a very common constituent of groundwater in southern Ontario and does not pose any health risk.

On December 23, 2005, Strathroy connected to the Lake Huron Water Supply System. Seven wells (well #8,9,13,11b,11d,14 and 15) were shut down when the connection was made. Additional distribution and reservoir work proposed in 2006 will enable the remaining six wells to be turned off in 2006.

Water Quality information pertaining to the new water supply (Lake Huron Primary Water System) may be obtained from the following web site and viewing the report tab.
www.watersupply.london.ca

List all water treatment chemicals used over this reporting period

Sodium Silicate – shut down December 23rd, 2005

Sodium Hypochlorite

Hydrochloric Acid – shut down December 23rd, 2005

Sodium Chlorite – shut down December 23rd, 2005

Chlorine Dioxide – shut down December 23rd, 2005

Were any significant expenses incurred to?

☐ Install required equipment

☒ Repair required equipment

☒ Replace required equipment

Describe

Six observation wells were decommissioned in 2005 as recommended by Wilson and Associates. All observation wells were inspected by Wilson and Associates. Well # 14 and Well #15 were cleaned and down hole video inspections were performed. The water tower was also inspected in 2005. Repairs were made to both reservoir booster pumps feeding into zone #2 (high pressure). The pipeline connection to Lake Huron was completed in December 2005. The Reservoir/Pumping Station improvements started in late 2005 and are scheduled for completion by September 30th, 2006

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Jan 14/05	York St. Well #13 Nitrate	10.6	mg/L	Resample	Jan 21/05
Jan 21/05	York St. Well #13 Nitrate	10.5	mg/L	Resample + Well #13 run only with well 8/9 Blend	Jan 25/05
Jan 21/05	390 York St. Downhams Nitrate	10.3	mg/L	MOH directed that additional distribution points should be collected	Jan 28/05
Feb 18/05	York St. Well #13 Nitrate	10.7	mg/L	Resample	Dec. 29/05
Feb 28/05	York St. Well #13 York Blend 8/9/13 S.P. Carroll/Parkview S.P. Carroll/Queen (Nitrates)	10.3 10.3 10.2 10.3	mg/L mg/L mg/L mg/L	Resample	Dec. 29/05
Mar 18/05	18 Calvin Ct 390 York St. 62 Parkview Cr. 187 Parkview Dr. S.P. Carroll/Parkview S.P. Carroll/Queen 91 Egerton St. (Nitrates)	10.3 10.3 10.3 10.3 10.2 10.3 10.3	mg/L mg/L mg/L mg/L mg/L mg/L mg/L	Drinking Water Advisory	Dec. 29/05
Mar 30/05	S.P. Carroll/Parkview York St. Well #8 York St. Well #9	10.1 10.1 10.5	mg/L mg/L mg/L	Drinking Water Advisory	Dec. 29/05

Drinking-Water Systems Regulation O. Reg. 170/03

	(Nitrates)				
May 17/05	Reservoir Total Coliforms	1	mfc/100 ml	Resample	May 24/05
May 16/05	York St. Well #8 York St. Well #9 York St. Well #13 (Nitrates)	10.2 11.3 10.8	mg/L mg/L mg/L	Drinking Water Advisory in place for nitrates	Dec 29/05
Aug 16/05	York St. Well #9 York St. Well #13 (Nitrates)	10.4 10.6	mg/L mg/L	Drinking Water Advisory in place for nitrates	Dec 29/05
Oct 14/05	390 York St. Downham S.P. Carroll/Parkview (Nitrates)	10.4 10.5	mg/L	Drinking Water Advisory in place for nitrates	Dec 29/05
Dec 8/05	York St. Well #8 York St. Well #9 York St. Well #13	10.1 10.6 11.0	mg/L	Drinking Water Advisory in place for nitrates	Dec 29/05

Microbiological testing done under section 8-2 during this reporting period

	Number of Samples	Range of E.Coli Or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of Samples Background Colony Counts	Range of Background Colony Counts (#-#)
Raw	598	0-50	0-A3C	584	0->2000
Treated	1067	0-0	0-0	1067	0-81
Distribution	329	0-1	0-0	329	0-96

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity	8760	0.002-5.09
Chlorine	8760	0.002-5.0
Chlorine Residual Distribution System	8760	0.005-1.77
Fluoride (If the DWS provides fluoridation)	N/A	

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is **not** milligrams per litre.

Well #1

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 17/05	0.6<MDL	ug/L	No
Arsenic	Nov 17/05	2<MDL	ug/L	No
Barium	Nov 17/05	30	ug/L	No
Boron	Nov 17/05	25	ug/L	No
Cadmium	Nov 17/05	0.1<MDL	ug/L	No
Chromium	Nov 17/05	3<MDL	ug/L	No
Lead			ug/L	No
Mercury	Nov 17/05	0.02	ug/L	No
Selenium	Nov 17/05	3<MDL	ug/L	No
Sodium	Jun 1/04	20.0	mg/L	No
Uranium	Nov 17/05	0.40	ug/L	No
Fluoride	Nov 24/04	0.2	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	6.32	mg/L	No
	May 16/05	6.35	mg/L	No
	Aug 16/05	5.88	mg/L	No
	Dec 8/05	5.90	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 17/05	0.11<MDL	ug/L	No
Aldicarb	Nov 17/05	0.30<MDL	ug/L	No
Aldrin + Dieldrin	Nov 17/05	0.067<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 17/05	0.12<MDL	ug/L	No
Azinphos-methyl	Nov 17/05	0.21<MDL	ug/L	No
Bendiocarb	Nov 17/05	0.13<MDL	ug/L	No
Benzene	Nov 17/05	0.35<MDL	ug/L	No
Benzo(a)pyrene	Nov 17/05	0.004<MDL	ug/L	No
Bromoxynil	Nov 17/05	0.094<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Carbaryl	Nov 17/05	0.16<MDL	ug/L	No
Carbofuran	Nov 17/05	0.37<MDL	ug/L	No
Carbon Tetrachloride	Nov 17/05	0.34<MDL	ug/L	No
Chlordane (Total)	Nov 17/05	0.31<MDL	ug/L	No
Chlorpyrifos	Nov 17/05	0.16<MDL	ug/L	No
Cyanazine	Nov 17/05	0.16<MDL	ug/L	No
Diazinon	Nov 17/05	0.08<MDL	ug/L	No
Dicamba	Nov 17/05	0.17<MDL	ug/L	No
1,2-Dichlorobenzene	Nov 17/05	0.56<MDL	ug/L	No
1,4-Dichlorobenzene	Nov 17/05	0.24<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 17/05	0.14<MDL	ug/L	No
1,2-Dichloroethane	Nov 17/05	0.32<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 17/05	0.52<MDL	ug/L	No
Dichloromethane	Nov 17/05	1.17<MDL	ug/L	No
2-4 Dichlorophenol	Nov 17/05	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 17/05	0.19<MDL	ug/L	No
Diclofop-methyl	Nov 17/05	0.13<MDL	ug/L	No
Dimethoate	Nov 17/05	0.12<MDL	ug/L	No
Dinoseb	Nov 17/05	0.084<MDL	ug/L	No
Diquat	Nov 17/05	1<MDL	ug/L	No
Diuron	Nov 17/05	0.067<MDL	ug/L	No
Glyphosate	Nov 17/05	6<MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 17/05	0.11<MDL	ug/L	No
Linadane (Total)	Nov 17/05	0.055<MDL	ug/L	No
Malathion	Nov 17/05	0.091<MDL	ug/L	No
Methoxychlor	Nov 17/05	0.14<MDL	ug/L	No
Metolachlor	Nov 17/05	0.092<MDL	ug/L	No
Metribuzin	Nov 17/05	0.12<MDL	ug/L	No
Monochlorobenzene	Nov 17/05	0.46<MDL	ug/L	No
Paraquat	Nov 17/05	1<MDL	ug/L	No
Parathion	Nov 17/05	0.18<MDL	ug/L	No
Pentachlorophenol	Nov 17/05	0.15<MDL	ug/L	No
Phorate	Nov 17/05	0.11<MDL	ug/L	No
Picloram	Nov 17/05	0.20<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 17/05	0.04<MDL	ug/L	No
Prometryne	Nov 17/05	0.23<MDL	ug/L	No
Simazine	Nov 17/05	0.15<MDL	ug/L	No
THM (NOTE: show latest annual average)	Nov 17/05		ug/L	No
Temephos	Nov 17/05	0.31<MDL	ug/L	No
Terbufos	Nov 17/05	0.12<MDL	ug/L	No
Tetrachloroethylene	Nov 17/05	0.48<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 17/05	0.14<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Triallate	Nov 17/05	0.10<MDL	ug/L	No
Trichloroethylene	Nov 17/05	0.54<MDL	ug/L	No
2,4,6-Trichlorophenol	Nov 17/05	0.25<MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 17/05	0.14<MDL	ug/L	No
Trifluralin	Nov 17/05	0.12<MDL	ug/L	No
Vinyl Chloride	Nov 17/05	0.08<MDL	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	6.32	mg/L	Feb 18/05
Nitrate	6.35	mg/L	May 16/05
Nitrate	5.88	mg/L	Aug 16/05
Nitrate	5.90	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #2

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 17/05	0.6<MDL	ug/L	No
Arsenic	Nov 17/05	2<MDL	ug/L	No
Barium	Nov 17/05	19	ug/L	No
Boron	Nov 17/05	24	ug/L	No
Cadmium	Nov 17/05	0.1<MDL	ug/L	No
Chromium	Nov 17/05	3<MDL	ug/L	No
Lead	Nov 17/05		ug/L	No
Mercury	Nov 17/05	0.02	ug/L	No
Selenium	Nov 17/05	3<MDL	ug/L	No
Sodium	Jun 1/04	17.9	mg/L	No
Uranium	Nov 17/05	0.27	ug/L	No
Fluoride	Nov 24/04	0.2	mg/l	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	6.52	mg/L	No
	May 16/05	6.77	mg/L	No
	Aug 16/05	6.08	mg/L	No
	Dec 8/05	5.55	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 17/05	0.11<MDL	ug/L	No
Aldicarb	Nov 17/05	0.30<MDL	ug/L	No
Aldrin + Dieldrin	Nov 17/05	0.067<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 17/05	0.12<MDL	ug/L	No
Azinphos-methyl	Nov 17/05	0.21<MDL	ug/L	No
Bendiocarb	Nov 17/05	0.13<MDL	ug/L	No
Benzene	Nov 17/05	0.35<MDL	ug/L	No
Benzo(a)pyrene	Nov 17/05	0.004<MDL	ug/L	No
Bromoxynil	Nov 17/05	0.094<MDL	ug/L	No
Carbaryl	Nov 17/05	0.16<MDL	ug/L	No
Carbofuran	Nov 17/05	0.37<MDL	ug/L	No
Carbon Tetrachloride	Nov 17/05	0.34<MDL	ug/L	No
Chlordane (Total)	Nov 17/05	0.31<MDL	ug/L	No
Chlorpyrifos	Nov 17/05	0.16<MDL	ug/L	No
Cyanazine	Nov 17/05	0.16<MDL	ug/L	No
Diazinon	Nov 17/05	0.08<MDL	ug/L	No
Dicamba	Nov 17/05	0.17<MDL	ug/L	No
1,2-Dichlorobenzene	Nov 17/05	0.56<MDL	ug/L	No
1,4-Dichlorobenzene	Nov 17/05	0.24<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 17/05	0.14<MDL	ug/L	No
1,2-Dichloroethane	Nov 17/05	0.32<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 17/05	0.52<MDL	ug/L	No
Dichloromethane	Nov 17/05	1.17<MDL	ug/L	No
2-4 Dichlorophenol	Nov 17/05	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 17/05	0.19<MDL	ug/L	No
Diclofop-methyl	Nov 17/05	0.13<MDL	ug/L	No
Dimethoate	Nov 17/05	0.12<MDL	ug/L	No
Dinoseb	Nov 17/05	0.084<MDL	ug/L	No
Diquat	Nov 17/05	1<MDL	ug/L	No
Diuron	Nov 17/05	0.067<MDL	ug/L	No
Glyphosate	Nov 17/05	6<MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 17/05	0.11<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Linadane (Total)	Nov 17/05	0.055<MDL	ug/L	No
Malathion	Nov 17/05	0.091<MDL	ug/L	No
Methoxychlor	Nov 17/05	0.14<MDL	ug/L	No
Metolachlor	Nov 17/05	0.092<MDL	ug/L	No
Metribuzin	Nov 17/05	0.12<MDL	ug/L	No
Monochlorobenzene	Nov 17/05	0.46<MDL	ug/L	No
Paraquat	Nov 17/05	1<MDL	ug/L	No
Parathion	Nov 17/05	0.18<MDL	ug/L	No
Pentachlorophenol	Nov 17/05	0.15<MDL	ug/L	No
Phorate	Nov 17/05	0.11<MDL	ug/L	No
Picloram	Nov 17/05	0.20<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 17/05	0.04<MDL	ug/L	No
Prometryne	Nov 17/05	0.23<MDL	ug/L	No
Simazine	Nov 17/05	0.15<MDL	ug/L	No
THM (NOTE: show latest annual average)	Nov 17/05		ug/L	No
Temephos	Nov 17/05	0.31<MDL	ug/L	No
Terbufos	Nov 17/05	0.12<MDL	ug/L	No
Tetrachloroethylene	Nov 17/05	0.48<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 17/05	0.14<MDL	ug/L	No
Triallate	Nov 17/05	0.10<MDL	ug/L	No
Trichloroethylene	Nov 17/05	0.54<MDL	ug/L	No
2,4,6-Trichlorophenol	Nov 17/05	0.25<MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 17/05	0.14<MDL	ug/L	No
Trifluralin	Nov 17/05	0.12<MDL	ug/L	No
Vinyl Chloride	Nov 17/05	0.08<MDL	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	6.52	mg/L	Feb 18/05
Nitrate	6.77	mg/L	May 16/05
Nitrate	6.08	mg/L	Aug 16/05
Nitrate	5.55	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #3

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 16/05	0.6<MDL	ug/L	No
Arsenic	Nov 16/05	2<MDL	ug/L	No
Barium	Nov 16/05	26	ug/L	No
Boron	Nov 16/05	25	ug/L	No
Cadmium	Nov 16/05	0.1<MDL	ug/L	No
Chromium	Nov 16/05	3<MDL	ug/L	No
Lead	Nov 16/05		ug/L	No
Mercury	Nov 16/05	0.03	ug/L	No
Selenium	Nov 16/05	3<MDL	ug/L	No
Sodium	Jun 1/04	13.0	mg/L	No
Uranium	Nov 16/05	0.25	ug/L	No
Fluoride	Nov 24/04	0.2	mg/L	No
Nitrite	Feb 18/05	N/A	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	N/A	mg/L	No
	May 16/05	8.8	mg/L	No
	Aug 16/05	9.18	mg/L	No
	Dec 8/05	7.86	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 16/05	0.11<MDL	ug/L	No
Aldicarb	Nov 16/05	0.30<MDL	ug/L	No
Aldrin + Dieldrin	Nov 16/05	0.067<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 16/05	0.12<MDL	ug/L	No
Azinphos-methyl	Nov 16/05	0.21<MDL	ug/L	No
Bendiocarb	Nov 16/05	0.13<MDL	ug/L	No
Benzene	Nov 16/05	0.35<MDL	ug/L	No
Benzo(a)pyrene	Nov 16/05	0.004<MDL	ug/L	No
Bromoxynil	Nov 16/05	0.094<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Carbaryl	Nov 16/05	0.16<MDL	ug/L	No
Carbofuran	Nov 16/05	0.37<MDL	ug/L	No
Carbon Tetrachloride	Nov 16/05	0.34<MDL	ug/L	No
Chlordane (Total)	Nov 16/05	0.31<MDL	ug/L	No
Chlorpyrifos	Nov 16/05	0.16<MDL	ug/L	No
Cyanazine	Nov 16/05	0.16<MDL	ug/L	No
Diazinon	Nov 16/05	0.08<MDL	ug/L	No
Dicamba	Nov 16/05	0.17<MDL	ug/L	No
1,2-Dichlorobenzene	Nov 16/05	0.56<MDL	ug/L	No
1,4-Dichlorobenzene	Nov 16/05	0.24<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 16/05	0.14<MDL	ug/L	No
1,2-Dichloroethane	Nov 16/05	0.32<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 16/05	0.52<MDL	ug/L	No
Dichloromethane	Nov 16/05	1.17<MDL	ug/L	No
2-4 Dichlorophenol	Nov 16/05	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 16/05	0.19<MDL	ug/L	No
Diclofop-methyl	Nov 16/05	0.13<MDL	ug/L	No
Dimethoate	Nov 16/05	0.12<MDL	ug/L	No
Dinoseb	Nov 16/05	0.084<MDL	ug/L	No
Diquat	Nov 16/05	1<MDL	ug/L	No
Diuron	Nov 16/05	0.067<MDL	ug/L	No
Glyphosate	Nov 16/05	6<MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 16/05	0.11<MDL	ug/L	No
Linadane (Total)	Nov 16/05	0.055<MDL	ug/L	No
Malathion	Nov 16/05	0.091<MDL	ug/L	No
Methoxychlor	Nov 16/05	0.14<MDL	ug/L	No
Metolachlor	Nov 16/05	0.092<MDL	ug/L	No
Metribuzin	Nov 16/05	0.12<MDL	ug/L	No
Monochlorobenzene	Nov 16/05	0.46<MDL	ug/L	No
Paraquat	Nov 16/05	1<MDL	ug/L	No
Parathion	Nov 16/05	0.18<MDL	ug/L	No
Pentachlorophenol	Nov 16/05	0.15<MDL	ug/L	No
Phorate	Nov 16/05	0.11<MDL	ug/L	No
Picloram	Nov 16/05	0.20<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 16/05	0.04<MDL	ug/L	No
Prometryne	Nov 16/05	0.23<MDL	ug/L	No
Simazine	Nov 16/05	0.15<MDL	ug/L	No
THM (NOTE: show latest annual average)			ug/L	No
Temephos	Nov 16/05	0.31<MDL	ug/L	No
Terbufos	Nov 16/05	0.12<MDL	ug/L	No
Tetrachloroethylene	Nov 16/05	0.48<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 16/05	0.14<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Triallate	Nov 16/05	0.10<MDL	ug/L	No
Trichloroethylene	Nov 16/05	0.54<MDL	ug/L	No
2,4,6-Trichlorophenol	Nov 16/05	0.25<MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 16/05	0.14<MDL	ug/L	No
Trifluralin	Nov 16/05	0.12<MDL	ug/L	No
Vinyl Chloride	Nov 16/05	0.08<MDL	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	8.8	mg/L	May 16/05
Nitrate	9.18	mg/L	Aug 16/05
Nitrate	7.86	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #4

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 16/05	0.6<MDL	ug/L	No
Arsenic	Nov 16/05	2<MDL	ug/L	No
Barium	Nov 16/05	53	ug/L	No
Boron	Nov 16/05	32	ug/L	No
Cadmium	Nov 16/05	0.1<MDL	ug/L	No
Chromium	Nov 16/05	3<MDL	ug/L	No
Lead	Nov 16/05		ug/L	No
Mercury	Nov 16/05	0.02<MDL	ug/L	No
Selenium	Nov 16/05	3<MDL	ug/L	No
Sodium	Jun 1/04	16.8	mg/L	No
Uranium	Nov 16/05	1.47	ug/L	No
Fluoride	Nov 24/04	0.2	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	5.67	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

	May 16/05	5.84	mg/L	No
	Aug 16/05	5.11	mg/L	No
	Dec 8/05	5.41	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 16/05	0.11<MDL	ug/L	No
Aldicarb	Nov 16/05	0.30<MDL	ug/L	No
Aldrin + Dieldrin	Nov 16/05	0.067<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 16/05	0.12<MDL	ug/L	No
Azinphos-methyl	Nov 16/05	0.21<MDL	ug/L	No
Bendiocarb	Nov 16/05	0.13<MDL	ug/L	No
Benzene	Nov 16/05	0.35<MDL	ug/L	No
Benzo(a)pyrene	Nov 16/05	0.004<MDL	ug/L	No
Bromoxynil	Nov 16/05	0.094<MDL	ug/L	No
Carbaryl	Nov 16/05	0.16<MDL	ug/L	No
Carbofuran	Nov 16/05	0.37<MDL	ug/L	No
Carbon Tetrachloride	Nov 16/05	0.34<MDL	ug/L	No
Chlordane (Total)	Nov 16/05	0.31<MDL	ug/L	No
Chlorpyrifos	Nov 16/05	0.16<MDL	ug/L	No
Cyanazine	Nov 16/05	0.16<MDL	ug/L	No
Diazinon	Nov 16/05	0.08<MDL	ug/L	No
Dicamba	Nov 16/05	0.17<MDL	ug/L	No
1,2-Dichlorobenzene	Nov 16/05	0.56<MDL	ug/L	No
1,4-Dichlorobenzene	Nov 16/05	0.24<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 16/05	0.14<MDL	ug/L	No
1,2-Dichloroethane	Nov 16/05	0.32<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 16/05	0.52<MDL	ug/L	No
Dichloromethane	Nov 16/05	1.17<MDL	ug/L	No
2-4 Dichlorophenol	Nov 16/05	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 16/05	0.19<MDL	ug/L	No
Diclofop-methyl	Nov 16/05	0.13<MDL	ug/L	No
Dimethoate	Nov 16/05	0.12<MDL	ug/L	No
Dinoseb	Nov 16/05	0.084<MDL	ug/L	No
Diquat	Nov 16/05	1<MDL	ug/L	No
Diuron	Nov 16/05	0.067<MDL	ug/L	No
Glyphosate	Nov 16/05	6<MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 16/05	0.11<MDL	ug/L	No
Linadane (Total)	Nov 16/05	0.055<MDL	ug/L	No
Malathion	Nov 16/05	0.091<MDL	ug/L	No

Methoxychlor	Nov 16/05	0.14<MDL	ug/L	No
Metolachlor	Nov 16/05	0.092<MDL	ug/L	No
Metribuzin	Nov 16/05	0.12<MDL	ug/L	No
Monochlorobenzene	Nov 16/05	0.46<MDL	ug/L	No
Paraquat	Nov 16/05	1<MDL	ug/L	No
Parathion	Nov 16/05	0.18<MDL	ug/L	No
Pentachlorophenol	Nov 16/05	0.15<MDL	ug/L	No
Phorate	Nov 16/05	0.11<MDL	ug/L	No
Picloram	Nov 16/05	0.20<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 16/05	0.04<MDL	ug/L	No
Prometryne	Nov 16/05	0.23<MDL	ug/L	No
Simazine	Nov 16/05	0.15<MDL	ug/L	No
THM (NOTE: show latest annual average)	Nov 16/05		ug/L	No
Temephos	Nov 16/05	0.31<MDL	ug/L	No
Terbufos	Nov 16/05	0.12<MDL	ug/L	No
Tetrachloroethylene	Nov 16/05	0.48<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 16/05	0.14<MDL	ug/L	No
Triallate	Nov 16/05	0.10<MDL	ug/L	No
Trichloroethylene	Nov 16/05	0.54<MDL	ug/L	No
2,4,6-Trichlorophenol	Nov 16/05	0.25<MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 16/05	0.14<MDL	ug/L	No
Trifluralin	Nov 16/05	0.12<MDL	ug/L	No
Vinyl Chloride	Nov 16/05	0.08<MDL	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	5.67	mg/L	Feb 18/05
Nitrate	5.84	mg/L	May 16/05
Nitrate	5.11	mg/L	Aug 16/05
Nitrate	5.41	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #5

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 16/05	0.6<MDL	ug/L	No
Arsenic	Nov 16/05	2<MDL	ug/L	No
Barium	Nov 16/05	58	ug/L	No
Boron	Nov 16/05	22	ug/L	No
Cadmium	Nov 16/05	0.1<MDL	ug/L	No
Chromium	Nov 16/05	3<MDL	ug/L	No
Lead	Nov 16/05		ug/L	No
Mercury	Nov 16/05	0.03	ug/L	No
Selenium	Nov 16/05	3<MDL	ug/L	No
Sodium	Jun 1/04	36.6	mg/L	Yes
Uranium	Nov 16/05	0.27	ug/L	No
Fluoride	Nov 25/04	ND	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	6	mg/L	No
	May 16/05	6.34	mg/L	No
	Aug 16/05	5.88	mg/L	No
	Dec 8/05	5.89	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 16/05	0.11<MDL	ug/L	No
Aldicarb	Nov 16/05	0.30<MDL	ug/L	No
Aldrin + Dieldrin	Nov 16/05	0.067<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 16/05	0.12<MDL	ug/L	No
Azinphos-methyl	Nov 16/05	0.21<MDL	ug/L	No
Bendiocarb	Nov 16/05	0.13<MDL	ug/L	No
Benzene	Nov 16/05	0.35<MDL	ug/L	No
Benzo(a)pyrene	Nov 16/05	0.004<MDL	ug/L	No
Bromoxynil	Nov 16/05	0.094<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Carbaryl	Nov 16/05	0.16<MDL	ug/L	No
Carbofuran	Nov 16/05	0.37<MDL	ug/L	No
Carbon Tetrachloride	Nov 16/05	0.34<MDL	ug/L	No
Chlordane (Total)	Nov 16/05	0.31<MDL	ug/L	No
Chlorpyrifos	Nov 16/05	0.16<MDL	ug/L	No
Cyanazine	Nov 16/05	0.16<MDL	ug/L	No
Diazinon	Nov 16/05	0.08<MDL	ug/L	No
Dicamba	Nov 16/05	0.17<MDL	ug/L	No
1,2-Dichlorobenzene	Nov 16/05	0.56<MDL	ug/L	No
1,4-Dichlorobenzene	Nov 16/05	0.24<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 16/05	0.14<MDL	ug/L	No
1,2-Dichloroethane	Nov 16/05	0.32<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 16/05	0.52<MDL	ug/L	No
Dichloromethane	Nov 16/05	1.17<MDL	ug/L	No
2-4 Dichlorophenol	Nov 16/05	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 16/05	0.19<MDL	ug/L	No
Diclofop-methyl	Nov 16/05	0.13<MDL	ug/L	No
Dimethoate	Nov 16/05	0.12<MDL	ug/L	No
Dinoseb	Nov 16/05	0.084<MDL	ug/L	No
Diquat	Nov 16/05	1<MDL	ug/L	No
Diuron	Nov 16/05	0.067<MDL	ug/L	No
Glyphosate	Nov 16/05	6<MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 16/05	0.11<MDL	ug/L	No
Linadane (Total)	Nov 16/05	0.055<MDL	ug/L	No
Malathion	Nov 16/05	0.091<MDL	ug/L	No
Methoxychlor	Nov 16/05	0.14<MDL	ug/L	No
Metolachlor	Nov 16/05	0.092<MDL	ug/L	No
Metribuzin	Nov 16/05	0.12<MDL	ug/L	No
Monochlorobenzene	Nov 16/05	0.46<MDL	ug/L	No
Paraquat	Nov 16/05	1<MDL	ug/L	No
Parathion	Nov 16/05	0.18<MDL	ug/L	No
Pentachlorophenol	Nov 16/05	0.15<MDL	ug/L	No
Phorate	Nov 16/05	0.11<MDL	ug/L	No
Picloram	Nov 16/05	0.20<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 16/05	0.04<MDL	ug/L	No
Prometryne	Nov 16/05	0.23<MDL	ug/L	No
Simazine	Nov 16/05	0.15<MDL	ug/L	No
THM (NOTE: show latest annual average)	Nov 16/05		ug/L	No
Temephos	Nov 16/05	0.31<MDL	ug/L	No
Terbufos	Nov 16/05	0.12<MDL	ug/L	No
Tetrachloroethylene	Nov 16/05	0.48<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 16/05	0.14<MDL	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Triallate	Nov 16/05	0.10<MDL	ug/L	No
Trichloroethylene	Nov 16/05	0.54<MDL	ug/L	No
2,4,6-Trichlorophenol	Nov 16/05	0.25<MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 16/05	0.14<MDL	ug/L	No
Trifluralin	Nov 16/05	0.12<MDL	ug/L	No
Vinyl Chloride	Nov 16/05	0.08<MDL	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	6	mg/L	Feb 18/05
Nitrate	6.34	mg/L	May 16/05
Nitrate	5.88	mg/L	Aug 16/05
Nitrate	5.89	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #6

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 16/05	0.6<MDL	ug/L	No
Arsenic	Nov 16/05	2<MDL	ug/L	No
Barium	Nov 16/05	37	ug/L	No
Boron	Nov 16/05	25	ug/L	No
Cadmium	Nov 16/05	0.1<MDL	ug/L	No
Chromium	Nov 16/05	3<MDL	ug/L	No
Lead	Nov 16/05		ug/L	No
Mercury	Nov 16/05	0.02<MDL	ug/L	No
Selenium	Nov 16/05	3<MDL	ug/L	No
Sodium	Jun 1/04	67.7	mg/L	Yes
Uranium	Nov 16/05	0.63	ug/L	No
Fluoride	Nov 24/04	ND	mg/L	No
Nitrite	Feb 18/05	0.01	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Nitrate	Feb 18/05	7.56	mg/L	No
	May 16/05	7.74	mg/L	No
	Aug 16/05	7.19	mg/L	No
	Dec 8/05	6.87	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 16/05	0.11<MDL	ug/L	No
Aldicarb	Nov 16/05	0.30<MDL	ug/L	No
Aldrin + Dieldrin	Nov 16/05	0.067<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 16/05	0.12<MDL	ug/L	No
Azinphos-methyl	Nov 16/05	0.21<MDL	ug/L	No
Bendiocarb	Nov 16/05	0.13<MDL	ug/L	No
Benzene	Nov 16/05	0.35<MDL	ug/L	No
Benzo(a)pyrene	Nov 16/05	0.004<MDL	ug/L	No
Bromoxynil	Nov 16/05	0.094<MDL	ug/L	No
Carbaryl	Nov 16/05	0.16<MDL	ug/L	No
Carbofuran	Nov 16/05	0.37<MDL	ug/L	No
Carbon Tetrachloride	Nov 16/05	0.34<MDL	ug/L	No
Chlordane (Total)	Nov 16/05	0.31<MDL	ug/L	No
Chlorpyrifos	Nov 16/05	0.16<MDL	ug/L	No
Cyanazine	Nov 16/05	0.16<MDL	ug/L	No
Diazinon	Nov 16/05	0.08<MDL	ug/L	No
Dicamba	Nov 16/05	0.17<MDL	ug/L	No
1,2-Dichlorobenzene	Nov 16/05	0.56<MDL	ug/L	No
1,4-Dichlorobenzene	Nov 16/05	0.24<MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 16/05	0.14<MDL	ug/L	No
1,2-Dichloroethane	Nov 16/05	0.32<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 16/05	0.52<MDL	ug/L	No
Dichloromethane	Nov 16/05	1.17<MDL	ug/L	No
2-4 Dichlorophenol	Nov 16/05	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 16/05	0.19<MDL	ug/L	No
Diclofop-methyl	Nov 16/05	0.13<MDL	ug/L	No
Dimethoate	Nov 16/05	0.12<MDL	ug/L	No
Dinoseb	Nov 16/05	0.084<MDL	ug/L	No
Diquat	Nov 16/05	1<MDL	ug/L	No
Diuron	Nov 16/05	0.067<MDL	ug/L	No
Glyphosate	Nov 16/05	6<MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 16/05	0.11<MDL	ug/L	No
Linadane (Total)	Nov 16/05	0.055<MDL	ug/L	No

Malathion	Nov 16/05	0.091<MDL	ug/L	No
Methoxychlor	Nov 16/05	0.14<MDL	ug/L	No
Metolachlor	Nov 16/05	0.092<MDL	ug/L	No
Metribuzin	Nov 16/05	0.12<MDL	ug/L	No
Monochlorobenzene	Nov 16/05	0.46<MDL	ug/L	No
Paraquat	Nov 16/05	1<MDL	ug/L	No
Parathion	Nov 16/05	0.18<MDL	ug/L	No
Pentachlorophenol	Nov 16/05	0.15<MDL	ug/L	No
Phorate	Nov 16/05	0.11<MDL	ug/L	No
Picloram	Nov 16/05	0.20<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 16/05	0.04<MDL	ug/L	No
Prometryne	Nov 16/05	0.23<MDL	ug/L	No
Simazine	Nov 16/05	0.15<MDL	ug/L	No
THM (NOTE: show latest annual average)	Nov 16/05		ug/L	No
Temephos	Nov 16/05	0.31<MDL	ug/L	No
Terbufos	Nov 16/05	0.12<MDL	ug/L	No
Tetrachloroethylene	Nov 16/05	0.48<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 16/05	0.14<MDL	ug/L	No
Triallate	Nov 16/05	0.10<MDL	ug/L	No
Trichloroethylene	Nov 16/05	0.54<MDL	ug/L	No
2,4,6-Trichlorophenol	Nov 16/05	0.25<MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 16/05	0.14<MDL	ug/L	No
Trifluralin	Nov 16/05	0.12<MDL	ug/L	No
Vinyl Chloride	Nov 16/05	0.08<MDL	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	7.56	mg/L	Feb 18/05
Nitrate	7.74	mg/L	May 16/05
Nitrate	7.19	mg/L	Aug 16/05
Nitrate	6.87	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #8

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure
Adverse Samples	Nitrate	Mar 30/05	10.1	mg/L

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 25/04	ND	mg/L	No
Arsenic	Nov 25/04	ND	mg/L	No
Barium	Nov 25/04	0.028	mg/L	No
Boron	Nov 25/04	0.11	mg/L	No
Cadmium	Nov 25/04	ND	mg/L	No
Chromium	Nov 25/04	ND	mg/L	No
Lead			mg/L	No
Mercury	Nov 25/04	ND	mg/L	No
Selenium	Nov 25/04	ND	mg/L	No
Sodium	Jun 1/04	7.20	mg/L	No
Uranium	Nov 25/04	ND	mg/L	No
Fluoride	Nov 25/04	ND	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	9.44	mg/L	No
	May 16/05	10.2	mg/L	Yes
	Aug 16/05	9.67	mg/L	No
	Dec 8/05	10.1	mg/L	Yes

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 25/04	ND	ug/L	No
Aldicarb	Nov 25/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 25/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 25/04	ND	ug/L	No
Azinphos-methyl	Nov 25/04	ND	ug/L	No
Bendiocarb	Nov 25/04	ND	ug/L	No
Benzene	Nov 25/04	ND	ug/L	No
Benzo(a)pyrene	Nov 25/04	ND	ug/L	No
Bromoxynil	Nov 25/04	ND	ug/L	No
Carbaryl	Nov 25/04	ND	ug/L	No

Carbofuran	Nov 25/04	ND	ug/L	No
Carbon Tetrachloride	Nov 25/04	ND	ug/L	No
Chlordane (Total)	Nov 25/04	ND	ug/L	No
Chlorpyrifos	Nov 25/04	ND	ug/L	No
Cyanazine	Nov 25/04	ND	ug/L	No
Diazinon	Nov 25/04	ND	ug/L	No
Dicamba	Nov 25/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 25/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 25/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 25/04	ND	ug/L	No
1,2-Dichloroethane	Nov 25/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 25/04	ND	ug/L	No
Dichloromethane	Nov 25/04	ND	ug/L	No
2-4 Dichlorophenol	Nov 25/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 25/04	ND	ug/L	No
Diclofop-methyl	Nov 25/04	ND	ug/L	No
Dimethoate	Nov 25/04	ND	ug/L	No
Dinoseb	Nov 25/04	ND	ug/L	No
Diquat	Nov 25/04	ND	ug/L	No
Diuron	Nov 25/04	ND	ug/L	No
Glyphosate	Nov 25/04	ND	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 25/04	ND	ug/L	No
Linadane (Total)	Nov 25/04	ND	ug/L	No
Malathion	Nov 25/04	ND	ug/L	No
Methoxychlor	Nov 25/04	ND	ug/L	No
Metolachlor	Nov 25/04	ND	ug/L	No
Metribuzin	Nov 25/04	ND	ug/L	No
Monochlorobenzene	Nov 25/04	ND	ug/L	No
Paraquat	Nov 25/04	ND	ug/L	No
Parathion	Nov 25/04	ND	ug/L	No
Pentachlorophenol	Nov 25/04	ND	ug/L	No
Phorate	Nov 25/04	ND	ug/L	No
Picloram	Nov 25/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 25/04	ND	ug/L	No
Prometryne	Nov 25/04	ND	ug/L	No
Simazine	Nov 25/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 25/04	ND	ug/L	No
Temephos	Nov 25/04	ND	ug/L	No
Terbufos	Nov 25/04	ND	ug/L	No
Tetrachloroethylene	Nov 25/04	ND	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 25/04	ND	ug/L	No
Triallate	Nov 25/04	ND	ug/L	No

Trichloroethylene	Nov 25/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 25/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 25/04	ND	ug/L	No
Trifluralin	Nov 25/04	ND	ug/L	No
Vinyl Chloride	Nov 25/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	9.44	mg/L	Feb 18/05
Nitrate	10.1	mg/L	Mar 30/05
Nitrate	10.2	mg/L	May 16/05
Nitrate	9.67	mg/L	Aug 16/05
Nitrate	10.1	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #9

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure
Adverse Samples	Nitrate	Mar 30/05	10.5	mg/L

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 25/04	ND	mg/L	No
Arsenic	Nov 25/04	ND	mg/L	No
Barium	Nov 25/04	0.027	mg/L	No
Boron	Nov 25/04	0.10	mg/L	No
Cadmium	Nov 25/04	ND	mg/L	No
Chromium	Nov 25/04	ND	mg/L	No
Lead			mg/L	No
Mercury	Nov 25/04	ND	mg/L	No
Selenium	Nov 25/04	ND	mg/L	No
Sodium	Jun 1/04	6.39	mg/L	No
Uranium	Nov 25/04	ND	mg/L	No
Fluoride	Feb 25/04	0.4	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Nitrate	Feb 18/05	10	mg/L	No
	May 16/05	11.3	mg/L	Yes
	Aug 16/05	10.4	mg/L	Yes
	Dec 8/05	10.6	mg/L	Yes

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 25/04	ND	ug/L	No
Aldicarb	Nov 25/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 25/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 25/04	ND	ug/L	No
Azinphos-methyl	Nov 25/04	ND	ug/L	No
Bendiocarb	Nov 25/04	ND	ug/L	No
Benzene	Nov 25/04	ND	ug/L	No
Benzo(a)pyrene	Nov 25/04	ND	ug/L	No
Bromoxynil	Nov 25/04	ND	ug/L	No
Carbaryl	Nov 25/04	ND	ug/L	No
Carbofuran	Nov 25/04	ND	ug/L	No
Carbon Tetrachloride	Nov 25/04	ND	ug/L	No
Chlordane (Total)	Nov 25/04	ND	ug/L	No
Chlorpyrifos	Nov 25/04	ND	ug/L	No
Cyanazine	Nov 25/04	ND	ug/L	No
Diazinon	Nov 25/04	ND	ug/L	No
Dicamba	Nov 25/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 25/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 25/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 25/04	ND	ug/L	No
1,2-Dichloroethane	Nov 25/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 25/04	ND	ug/L	No
Dichloromethane	Nov 25/04	ND	ug/L	No
2-4 Dichlorophenol	Nov 25/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 25/04	ND	ug/L	No
Diclofop-methyl	Nov 25/04	ND	ug/L	No
Dimethoate	Nov 25/04	ND	ug/L	No
Dinoseb	Nov 25/04	ND	ug/L	No
Diquat	Nov 25/04	ND	ug/L	No
Diuron	Nov 25/04	ND	ug/L	No
Glyphosate	Nov 25/04	ND	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 25/04	ND	ug/L	No
Linadane (Total)	Nov 25/04	ND	ug/L	No
Malathion	Nov 25/04	ND	ug/L	No
Methoxychlor	Nov 25/04	ND	ug/L	No

Metolachlor	Nov 25/04	ND	ug/L	No
Metribuzin	Nov 25/04	ND	ug/L	No
Monochlorobenzene	Nov 25/04	ND	ug/L	No
Paraquat	Nov 25/04	ND	ug/L	No
Parathion	Nov 25/04	ND	ug/L	No
Pentachlorophenol	Nov 25/04	ND	ug/L	No
Phorate	Nov 25/04	ND	ug/L	No
Picloram	Nov 25/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 25/04	ND	ug/L	No
Prometryne	Nov 25/04	ND	ug/L	No
Simazine	Nov 25/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 25/04	ND	ug/L	No
Temephos	Nov 25/04	ND	ug/L	No
Terbufos	Nov 25/04	ND	ug/L	No
Tetrachloroethylene	Nov 25/04	ND	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 25/04	ND	ug/L	No
Triallate	Nov 25/04	ND	ug/L	No
Trichloroethylene	Nov 25/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 25/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 25/04	ND	ug/L	No
Trifluralin	Nov 25/04	ND	ug/L	No
Vinyl Chloride	Nov 25/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	10	mg/L	Feb 18/05
Nitrate	10.5	mg/L	Mar 30/05
Nitrate	11.3	mg/L	May 16/05
Nitrate	10.4	mg/L	Aug 16/05
Nitrate	10.6	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #11B

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 24/04	ND	mg/L	No
Arsenic	Nov 24/04	0.0017	mg/L	No
Barium	Nov 24/04	0.060	mg/L	No
Boron	Nov 24/04	0.007	mg/L	No
Cadmium	Nov 24/04	ND	mg/L	No
Chromium	Nov 24/04	0.0023	mg/L	No
Lead			mg/L	No
Mercury	Nov 24/04	ND	mg/L	No
Selenium	Nov 24/04	ND	mg/L	No
Sodium	Jun 1/04	12.3	mg/L	No
Uranium	Nov 24/04	ND	mg/L	No
Fluoride	Nov 25/04	0.2	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	0.015	mg/L	No
	May 16/05	0.58	mg/L	No
	Aug 16/05	0.11	mg/L	No
	Dec 8/05	3.08	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 24/04	ND	ug/L	No
Aldicarb	Nov 24/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 24/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 24/04	ND	ug/L	No
Azinphos-methyl	Nov 24/04	ND	ug/L	No
Bendiocarb	Nov 24/04	ND	ug/L	No
Benzene	Nov 24/04	ND	ug/L	No
Benzo(a)pyrene	Nov 24/04	ND	ug/L	No
Bromoxynil	Nov 24/04	ND	ug/L	No
Carbaryl	Nov 24/04	ND	ug/L	No

Carbofuran	Nov 24/04	ND	ug/L	No
Carbon Tetrachloride	Nov 24/04	ND	ug/L	No
Chlordane (Total)	Nov 24/04	ND	ug/L	No
Chlorpyrifos	Nov 24/04	ND	ug/L	No
Cyanazine	Nov 24/04	ND	ug/L	No
Diazinon	Nov 24/04	ND	ug/L	No
Dicamba	Nov 24/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 24/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 24/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 24/04	ND	ug/L	No
1,2-Dichloroethane	Nov 24/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 24/04	ND	ug/L	No
Dichloromethane	Nov 24/04	ND	ug/L	No
2-4 Dichlorophenol	Nov 24/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 24/04	ND	ug/L	No
Diclofop-methyl	Nov 24/04	ND	ug/L	No
Dimethoate	Nov 24/04	ND	ug/L	No
Dinoseb	Nov 24/04	ND	ug/L	No
Diquat	Nov 24/04	ND	ug/L	No
Diuron	Nov 24/04	ND	ug/L	No
Glyphosate	Nov 24/04	ND	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 24/04	ND	ug/L	No
Linadane (Total)	Nov 24/04	ND	ug/L	No
Malathion	Nov 24/04	ND	ug/L	No
Methoxychlor	Nov 24/04	ND	ug/L	No
Metolachlor	Nov 24/04	ND	ug/L	No
Metribuzin	Nov 24/04	ND	ug/L	No
Monochlorobenzene	Nov 24/04	ND	ug/L	No
Paraquat	Nov 24/04	ND	ug/L	No
Parathion	Nov 24/04	ND	ug/L	No
Pentachlorophenol	Nov 24/04	ND	ug/L	No
Phorate	Nov 24/04	ND	ug/L	No
Picloram	Nov 24/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 24/04	ND	ug/L	No
Prometryne	Nov 24/04	ND	ug/L	No
Simazine	Nov 24/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 24/04	ND	ug/L	No
Temephos	Nov 24/04	ND	ug/L	No
Terbufos	Nov 24/04	ND	ug/L	No
Tetrachloroethylene	Nov 24/04	ND	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 24/04	ND	ug/L	No
Triallate	Nov 24/04	ND	ug/L	No

Trichloroethylene	Nov 24/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 24/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 24/04	ND	ug/L	No
Trifluralin	Nov 24/04	ND	ug/L	No
Vinyl Chloride	Nov 24/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #11D

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 24/04	ND	mg/L	No
Arsenic	Nov 24/04	ND	mg/L	No
Barium	Nov 24/04	0.073	mg/L	No
Boron	Nov 24/04	0.008	mg/L	No
Cadmium	Nov 24/04	ND	mg/L	No
Chromium	Nov 24/04	ND	mg/L	No
Lead			mg/L	No
Mercury	Nov 24/04	ND	mg/L	No
Selenium	Nov 24/04	ND	mg/L	No
Sodium	Jun 1/04	14.4	mg/L	No
Uranium	Nov 24/04	ND	mg/L	No
Fluoride	Nov 24/04	0.2	mg/L	No
Nitrite	Feb 18/05	0.005	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	0.214	mg/L	No
	May 16/05	0.923	mg/L	No
	Aug 16/05	0.92	mg/L	No

	Dec 8/05	0.175	mg/L	No
--	----------	-------	------	----

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 24/04	ND	ug/L	No
Aldicarb	Nov 24/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 24/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 24/04	ND	ug/L	No
Azinphos-methyl	Nov 24/04	ND	ug/L	No
Bendiocarb	Nov 24/04	ND	ug/L	No
Benzene	Nov 24/04	ND	ug/L	No
Benzo(a)pyrene	Nov 24/04	ND	ug/L	No
Bromoxynil	Nov 24/04	ND	ug/L	No
Carbaryl	Nov 24/04	ND	ug/L	No
Carbofuran	Nov 24/04	ND	ug/L	No
Carbon Tetrachloride	Nov 24/04	ND	ug/L	No
Chlordane (Total)	Nov 24/04	ND	ug/L	No
Chlorpyrifos	Nov 24/04	ND	ug/L	No
Cyanazine	Nov 24/04	ND	ug/L	No
Diazinon	Nov 24/04	ND	ug/L	No
Dicamba	Nov 24/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 24/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 24/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 24/04	ND	ug/L	No
1,2-Dichloroethane	Nov 24/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 24/04	ND	ug/L	No
Dichloromethane	Nov 24/04	ND	ug/L	No
2,4 Dichlorophenol	Nov 24/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 24/04	ND	ug/L	No
Diclofop-methyl	Nov 24/04	ND	ug/L	No
Dimethoate	Nov 24/04	ND	ug/L	No
Dinoseb	Nov 24/04	ND	ug/L	No
Diquat	Nov 24/04	ND	ug/L	No
Diuron	Nov 24/04	ND	ug/L	No
Glyphosate	Nov 24/04	ND	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 24/04	ND	ug/L	No
Linadane (Total)	Nov 24/04	ND	ug/L	No
Malathion	Nov 24/04	ND	ug/L	No
Methoxychlor	Nov 24/04	ND	ug/L	No
Metolachlor	Nov 24/04	ND	ug/L	No
Metribuzin	Nov 24/04	ND	ug/L	No
Monochlorobenzene	Nov 24/04	ND	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Paraquat	Nov 24/04	ND	ug/L	No
Parathion	Nov 24/04	ND	ug/L	No
Pentachlorophenol	Nov 24/04	ND	ug/L	No
Phorate	Nov 24/04	ND	ug/L	No
Picloram	Nov 24/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 24/04	ND	ug/L	No
Prometryne	Nov 24/04	ND	ug/L	No
Simazine	Nov 24/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 24/04	ND	ug/L	No
Temephos	Nov 24/04	ND	ug/L	No
Terbufos	Nov 24/04	ND	ug/L	No
Tetrachloroethylene	Nov 24/04	ND	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 24/04	ND	ug/L	No
Triallate	Nov 24/04	ND	ug/L	No
Trichloroethylene	Nov 24/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 24/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 24/04	ND	ug/L	No
Trifluralin	Nov 24/04	ND	ug/L	No
Vinyl Chloride	Nov 24/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #13

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure
Adverse Resample	Nitrate	Jan 14/05	10.6	mg/L
Adverse Resample	Nitrate	Jan 21/05	10.5	mg/L
Adverse Resample	Nitrate	Feb 28/05	10.3	mg/L
Adverse Resample	Nitrate	May 16/05	10.8	mg/L

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 25/04	ND	mg/L	No
Arsenic	Nov 25/04	ND	mg/L	No
Barium	Nov 25/04	0.035	mg/L	No
Boron	Nov 25/04	0.017	mg/L	No
Cadmium	Nov 25/04	ND	mg/L	No
Chromium	Nov 25/04	0.0026	mg/L	No
Lead			mg/L	No
Mercury	Nov 25/04	ND	mg/L	No
Selenium	Nov 25/04	ND	mg/L	No
Sodium	Jun 1/04	9.53	mg/L	No
Uranium	Nov 25/04	0.0025	mg/L	No
Fluoride	Feb 25/04	0.2	mg/L	No
Nitrite	Feb 18/05	0.01	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	10.7	mg/L	Yes
	May 16/05	10.8	mg/L	Yes
	Aug 16/05	10.6	mg/L	Yes
	Dec 8/05	11.0	mg/L	Yes

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 25/04	ND	ug/L	No
Aldicarb	Nov 25/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 25/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 25/04	ND	ug/L	No
Azinphos-methyl	Nov 25/04	ND	ug/L	No
Bendiocarb	Nov 25/04	ND	ug/L	No
Benzene	Nov 25/04	ND	ug/L	No
Benzo(a)pyrene	Nov 25/04	ND	ug/L	No

Bromoxynil	Nov 25/04	ND	ug/L	No
Carbaryl	Nov 25/04	ND	ug/L	No
Carbofuran	Nov 25/04	ND	ug/L	No
Carbon Tetrachloride	Nov 25/04	ND	ug/L	No
Chlordane (Total)	Nov 25/04	ND	ug/L	No
Chlorpyrifos	Nov 25/04	ND	ug/L	No
Cyanazine	Nov 25/04	ND	ug/L	No
Diazinon	Nov 25/04	ND	ug/L	No
Dicamba	Nov 25/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 25/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 25/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 25/04	ND	ug/L	No
1,2-Dichloroethane	Nov 25/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 25/04	ND	ug/L	No
Dichloromethane	Nov 25/04	ND	ug/L	No
2-4 Dichlorophenol	Nov 25/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 25/04	ND	ug/L	No
Diclofop-methyl	Nov 25/04	ND	ug/L	No
Dimethoate	Nov 25/04	ND	ug/L	No
Dinoseb	Nov 25/04	ND	ug/L	No
Diquat	Nov 25/04	ND	ug/L	No
Diuron	Nov 25/04	ND	ug/L	No
Glyphosate	Nov 25/04	ND	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 25/04	ND	ug/L	No
Linadane (Total)	Nov 25/04	ND	ug/L	No
Malathion	Nov 25/04	ND	ug/L	No
Methoxychlor	Nov 25/04	ND	ug/L	No
Metolachlor	Nov 25/04	ND	ug/L	No
Metribuzin	Nov 25/04	ND	ug/L	No
Monochlorobenzene	Nov 25/04	ND	ug/L	No
Paraquat	Nov 25/04	ND	ug/L	No
Parathion	Nov 25/04	ND	ug/L	No
Pentachlorophenol	Nov 25/04	ND	ug/L	No
Phorate	Nov 25/04	ND	ug/L	No
Picloram	Nov 25/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 25/04	ND	ug/L	No
Prometryne	Nov 25/04	ND	ug/L	No
Simazine	Nov 25/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 25/04	ND	ug/L	No
Temephos	Nov 25/04	ND	ug/L	No
Terbufos	Nov 25/04	ND	ug/L	No
Tetrachloroethylene	Nov 25/04	ND	ug/L	No

2,3,4,6-Tetrachlorophenol	Nov 25/04	ND	ug/L	No
Triallate	Nov 25/04	ND	ug/L	No
Trichloroethylene	Nov 25/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 25/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 25/04	ND	ug/L	No
Trifluralin	Nov 25/04	ND	ug/L	No
Vinyl Chloride	Nov 25/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	10.6	mg/L	Jan 14/05
Nitrate	10.5	mg/L	Jan 21/05
Nitrate	10.7	mg/L	Feb 18/05
Nitrate	10.3	mg/L	Feb 28/05
Nitrate	10.8	mg/L	May 16/05
Nitrate	10.6	mg/L	Aug 16/05
Nitrate	11.0	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #14

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 25/04	ND	mg/L	No
Arsenic	Nov 25/04	ND	mg/L	No
Barium	Nov 25/04	0.053	mg/L	No
Boron	Nov 25/04	0.009	mg/L	No
Cadmium	Nov 25/04	ND	mg/L	No
Chromium	Nov 25/04	0.0021	mg/L	No
Lead			mg/L	No
Mercury	Nov 25/04	ND	mg/L	No
Selenium	Nov 25/04	ND	mg/L	No
Sodium	Jun 1/04	10.7	mg/L	No
Uranium	Nov 25/04	ND	mg/L	No
Fluoride	Nov 25/04	ND	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Nitrite	Feb 18/05	N/A	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	N/A	mg/L	No
	May 16/05	2.16	mg/L	No
	Aug 16/05	9.05	mg/L	No
	Dec 8/05	5.46	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 25/04	ND	ug/L	No
Aldicarb	Nov 25/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 25/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 25/04	ND	ug/L	No
Azinphos-methyl	Nov 25/04	ND	ug/L	No
Bendiocarb	Nov 25/04	ND	ug/L	No
Benzene	Nov 25/04	ND	ug/L	No
Benzo(a)pyrene	Nov 25/04	ND	ug/L	No
Bromoxynil	Nov 25/04	ND	ug/L	No
Carbaryl	Nov 25/04	ND	ug/L	No
Carbofuran	Nov 25/04	ND	ug/L	No
Carbon Tetrachloride	Nov 25/04	ND	ug/L	No
Chlordane (Total)	Nov 25/04	ND	ug/L	No
Chlorpyrifos	Nov 25/04	ND	ug/L	No
Cyanazine	Nov 25/04	ND	ug/L	No
Diazinon	Nov 25/04	ND	ug/L	No
Dicamba	Nov 25/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 25/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 25/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 25/04	ND	ug/L	No
1,2-Dichloroethane	Nov 25/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 25/04	ND	ug/L	No
Dichloromethane	Nov 25/04	ND	ug/L	No
2,4-Dichlorophenol	Nov 25/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 25/04	ND	ug/L	No
Diclofop-methyl	Nov 25/04	ND	ug/L	No
Dimethoate	Nov 25/04	ND	ug/L	No
Dinoseb	Nov 25/04	ND	ug/L	No
Diquat	Nov 25/04	ND	ug/L	No
Diuron	Nov 25/04	ND	ug/L	No
Glyphosate	Nov 25/04	ND	ug/L	No

Heptachlor + Heptachlor Epoxide	Nov 25/04	ND	ug/L	No
Linadane (Total)	Nov 25/04	ND	ug/L	No
Malathion	Nov 25/04	ND	ug/L	No
Methoxychlor	Nov 25/04	ND	ug/L	No
Metolachlor	Nov 25/04	ND	ug/L	No
Metribuzin	Nov 25/04	ND	ug/L	No
Monochlorobenzene	Nov 25/04	ND	ug/L	No
Paraquat	Nov 25/04	ND	ug/L	No
Parathion	Nov 25/04	ND	ug/L	No
Pentachlorophenol	Nov 25/04	ND	ug/L	No
Phorate	Nov 25/04	ND	ug/L	No
Picloram	Nov 25/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 25/04	ND	ug/L	No
Prometryne	Nov 25/04	ND	ug/L	No
Simazine	Nov 25/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 25/04	ND	ug/L	No
Temephos	Nov 25/04	ND	ug/L	No
Terbufos	Nov 25/04	ND	ug/L	No
Tetrachloroethylene	Nov 25/04	ND	ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 25/04	ND	ug/L	No
Triallate	Nov 25/04	ND	ug/L	No
Trichloroethylene	Nov 25/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 25/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 25/04	ND	ug/L	No
Trifluralin	Nov 25/04	ND	ug/L	No
Vinyl Chloride	Nov 25/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	9.05	mg/L	Aug 16/05
Nitrate	5.46	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Well #15

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Nov 24/04	ND	mg/L	No
Arsenic	Nov 24/04	ND	mg/L	No
Barium	Nov 24/04	0.040	mg/L	No
Boron	Nov 24/04	0.009	mg/L	No
Cadmium	Nov 24/04	ND	mg/L	No
Chromium	Nov 24/04	0.0029	mg/L	No
Lead			mg/L	No
Mercury	Nov 24/04	ND	mg/L	No
Selenium	Nov 24/04	ND	mg/L	No
Sodium	Jun 1/04	11.3	mg/L	No
Uranium	Nov 24/04	ND	mg/L	No
Fluoride	Nov 24/04	0.3	mg/L	No
Nitrite	Feb 18/05	N/A	mg/L	No
	May 16/05	0.005	mg/L	No
	Aug 16/05	0.005	mg/L	No
	Dec 8/05	0.005<MDL	mg/L	No
Nitrate	Feb 18/05	N/A	mg/L	No
	May 16/05	9.97	mg/L	No
	Aug 16/05	9.91	mg/L	No
	Dec 8/05	9.30	mg/L	No

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Nov 24/04	ND	ug/L	No
Aldicarb	Nov 24/04	ND	ug/L	No
Aldrin + Dieldrin	Nov 24/04	ND	ug/L	No
Atrazine + N-dealkylated metabolites	Nov 24/04	ND	ug/L	No
Azinphos-methyl	Nov 24/04	ND	ug/L	No
Bendiocarb	Nov 24/04	ND	ug/L	No
Benzene	Nov 24/04	ND	ug/L	No
Benzo(a)pyrene	Nov 24/04	ND	ug/L	No
Bromoxynil	Nov 24/04	ND	ug/L	No
Carbaryl	Nov 24/04	ND	ug/L	No

Carbofuran	Nov 24/04	ND	ug/L	No
Carbon Tetrachloride	Nov 24/04	ND	ug/L	No
Chlordane (Total)	Nov 24/04	ND	ug/L	No
Chlorpyrifos	Nov 24/04	ND	ug/L	No
Cyanazine	Nov 24/04	ND	ug/L	No
Diazinon	Nov 24/04	ND	ug/L	No
Dicamba	Nov 24/04	ND	ug/L	No
1,2-Dichlorobenzene	Nov 24/04	ND	ug/L	No
1,4-Dichlorobenzene	Nov 24/04	ND	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Nov 24/04	ND	ug/L	No
1,2-Dichloroethane	Nov 24/04	ND	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Nov 24/04	ND	ug/L	No
Dichloromethane	Nov 24/04	ND	ug/L	No
2-4 Dichlorophenol	Nov 24/04	ND	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Nov 24/04	ND	ug/L	No
Diclofop-methyl	Nov 24/04	ND	ug/L	No
Dimethoate	Nov 24/04	ND	ug/L	No
Dinoseb	Nov 24/04	ND	ug/L	No
Diquat	Nov 24/04	ND	ug/L	No
Diuron	Nov 24/04	ND	ug/L	No
Glyphosate	Nov 24/04	ND	ug/L	No
Heptachlor + Heptachlor Epoxide	Nov 24/04	ND	ug/L	No
Linadane (Total)	Nov 24/04	ND	ug/L	No
Malathion	Nov 24/04	ND	ug/L	No
Methoxychlor	Nov 24/04	ND	ug/L	No
Metolachlor	Nov 24/04	ND	ug/L	No
Metribuzin	Nov 24/04	ND	ug/L	No
Monochlorobenzene	Nov 24/04	ND	ug/L	No
Paraquat	Nov 24/04	ND	ug/L	No
Parathion	Nov 24/04	ND	ug/L	No
Pentachlorophenol	Nov 24/04	ND	ug/L	No
Phorate	Nov 24/04	ND	ug/L	No
Picloram	Nov 24/04	ND	ug/L	No
Polychlorinated Biphenyls(PCB)	Nov 24/04	ND	ug/L	No
Prometryne	Nov 24/04	ND	ug/L	No
Simazine	Nov 24/04	ND	ug/L	No
THM (NOTE: show latest annual average)	Nov 24/04	ND	ug/L	No
Temephos	Nov 24/04	ND	ug/L	No
Terbufos	Nov 24/04	ND	ug/L	No
Tetrachloroethylene	Nov 24/04		ug/L	No
2,3,4,6-Tetrachlorophenol	Nov 24/04	ND	ug/L	No
Triallate	Nov 24/04	ND	ug/L	No

Trichloroethylene	Nov 24/04	ND	ug/L	No
2,4,6-Trichlorophenol	Nov 24/04	ND	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Nov 24/04	ND	ug/L	No
Trifluralin	Nov 24/04	ND	ug/L	No
Vinyl Chloride	Nov 24/04	ND	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nitrate	9.97	mg/L	May 16/05
Nitrate	9.91	mg/L	Aug 16/05
Nitrate	9.30	mg/L	Dec 8/05

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

End of Distribution Sample (3230 Naperton)

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead	Nov 17/05	0.7	ug/L	No
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2,4-Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Linadane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				

Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: show latest annual average)	Feb 18/05 Aug 16/05 May16/05 Nov 17/05	3.8 3.5 3.8 9.0	ug/L ug/L ug/L ug/L	No No No No
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

Additional Well/Distribution Samples Collected (Drinking Water Advisory Nitrates)

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters (Nitrate) tested during this reporting period or most recent

Site	Sample Date	Result Value	Unit of Measure	Exceedance
York St. Well #8	Jan 14/05	9.8	mg/L	No
York St. Well #13	Jan 14/05	10.6	mg/L	Yes
York St. Blended (8,9,13)	Jan 14/05	10	mg/L	No
390 York St. (Downhams)	Jan 14/05	10	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

York St. Well #13	Jan 21/05	10.5	mg/L	Yes
York St. Blended (8,9,13)	Jan 21/05	9.8	mg/L	No
390 York St. (Downhams)	Jan 21/05	10.3	mg/L	Yes
Queen St. Sample Station	Jan 28/05	9.5	mg/L	No
Queen St. Sample Station	Feb 1/05	9.6	mg/L	No
Carroll/Parkview Sample	Feb 1/05	9.5	mg/L	No
184 Parkview	Feb 1/05	9.5	mg/L	No
York St. Well #13	Feb 28/05	10.3	mg/L	Yes
York St. Blended (8,9,13)	Feb 28/05	10.3	mg/L	Yes
S.P. Carroll/Parkview	Feb 28/05	10.2	mg/L	Yes
S.P. Carroll/Queen	Feb 28/05	10.3	mg/L	Yes
18 Calvin St.	Mar 18/05	10.3	mg/L	Yes
390 York St.	Mar 18/05	10.3	mg/L	Yes
62 Parkview Cr.	Mar 18/05	10.3	mg/L	Yes
187 Parkview Drive	Mar 18/05	10.3	mg/L	Yes
S.P. Carroll/Parkview	Mar 18/05	10.2	mg/L	Yes
S.P. Carroll/Queen	Mar 18/05	10.3	mg/L	Yes
91 Egerton	Mar 18/05	10.3	mg/L	Yes
351 Frances St.	Mar 18/05	9.09	mg/L	No
18 Calvin Ct	Mar 26/05	4.50	mg/L	No
62 Parkview Cr.	Mar 26/05	0.562	mg/L	No
184 Parkview Dr.	Mar 26/05	0.456	mg/L	No
S.P. Carroll/Parkview	Mar 26/05	3.64	mg/L	No
S.P. Carroll/Queen	Mar 26/05	0.074	mg/L	No
91 Egerton St.	Mar 26/05	2.96	mg/L	No
351 Frances St.	Mar 26/05	8.00	mg/L	No
168 Metcalfe St.	Mar 26/05	5.33	mg/L	No
127 Queen St.	Mar 26/05	2.45	mg/L	No
352 High St.	Mar 26/05	1.06	mg/L	No
75 Caradoc St.	Mar 26/05	6.38	mg/L	No
3230 Napperton	Mar 26/05	4.92	mg/L	No
Gemini Sportsplex	Mar 26/05	7.25	mg/L	No
Middlesex Memorial Arena	Mar 26/05	3.92	mg/L	No
S.P. Carrie/Hospital	Mar 26/05	5.73	mg/L	No
TW Well #8	Mar 26/05	9.34	mg/L	No
TW Well #9	Mar 26/05	9.08	mg/L	No
TW Well # 8/9 Combined	Mar 26/05	9.07	mg/L	No
TW Bosquart Well 11B	Mar 29/05	0.015	mg/L	No
TW Bosquart Well 11D	Mar 29/05	0.214	mg/L	No
TDW SP Carroll/Parkview	Mar 30/05	10.1	mg/L	Yes
91 Egerton	Mar 30/05	6.68	mg/L	No
351 Frances	Mar 30/05	2.15	mg/L	No
168 Metcalfe St.	Mar 30/05	4.46	mg/L	No
127 Queen St.	Mar 30/05	3.41	mg/L	No

352 High St.	Mar 30/05	3.16	mg/L	No
75 Caradoc St.	Mar 30/05	6.45	mg/L	No
3230 Napperton Dr.	Mar 30/05	5.27	mg/L	No
Gemini Sportsplex	Mar 30/05	7.80	mg/L	No
Middlesex Memorial Arena	Mar 30/05	3.51	mg/L	No
S.P. Carrie/Hospital	Mar 30/05	4.75	mg/L	No
Reservoir Inlet	Mar 30/05	5.35	mg/L	No
TDW Well #8	Mar 30/05	10.1	mg/L	Yes
TDW Well #9	Mar 30/05	10.5	mg/L	Yes
TDW Well 8/9 Blend	Mar 30/05	10.5	mg/L	Yes
390 York Downhams	Mar 30/05	3.24	mg/L	No
62 Parkview Cr.	Mar 30/05	0.415	mg/L	No
188 Parkview Dr.	Mar 30/05	9.91	mg/L	No
S.P. Carroll/Queen	Mar 30/05	0.084	mg/L	No
TDW 390 York Downhams	Apr 12/05	9.78	mg/L	No
S.P. Carroll/Parkview	Apr 12/05	9.83	mg/L	No
390 York St. Downhams	May 16/05	4.90	mg/L	No
S.P. Carroll/Parlview	May 16/05	4.51	mg/L	No
S.P. Carroll/Parkview	Jun 14/05	2.84	mg/L	No
390 York St. Downhams	Jun 14/05	4.44	mg/L	No
390 York St. Downhams	Jul 13/05	9.49	mg/L	No
S.P. Carroll/Parkview	Jul 13/05	9.41	mg/L	No
390 York St. Downhams	Aug 16/05	5.40	mg/L	No
S.P. Carroll/Parkview	Aug 16/05	9.50	mg/L	No
390 York St. Downhams	Sep 20/05	3.49	mg/L	No
S.P. Carroll/Parkview	Sep 20/05	8.78	mg/L	No
390 York St. Downhams	Oct 14/05	10.4	mg/L	Yes
S.P. Carroll/Parkview	Oct 14/05	10.5	mg/L	Yes
390 York St. Downhams	Nov 17/05	6.18	mg/L	No
S.P. Carroll/Parkview	Nov 17/05	3.19	mg/L	No
390 York St. Downhams	Dec 8/05	4.64	mg/L	No
S.P. Carroll/Parkview	Dec 8/05	9.79	mg/L	No
3230 Napperton	Dec 22/05	6.59	mg/L	No
263 Pine Tree	Dec 22/05	6.09	mg/L	No
47 Parkview Cr	Dec 22/05	7.03	mg/L	No
351 Frances St.	Dec 22/05	6.84	mg/L	No
390 York St. Downhams	Dec 22/05	7.81	mg/L	No
S.P. Carroll @ Parkview	Dec 22/05	7.31	mg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Site	Parameter	Result Value	Unit of Measure	Date of Sample
York St. Well #8	Nitrate	9.8	mg/L	Jan 14/05
York St. Well #13	Nitrate	10.6	mg/L	Jan 14/05
York St. Blended (8,9,13)	Nitrate	10	mg/L	Jan 14/05
390 York St. (Downhams)	Nitrate	10	mg/L	Jan 14/05
York St. Well #13	Nitrate	10.5	mg/L	Jan 21/05
York St. Blended (8,9,13)	Nitrate	9.8	mg/L	Jan 21/05
390 York St. (Downhams)	Nitrate	10.3	mg/L	Jan 21/05
Queen St. Sample Station	Nitrate	9.5	mg/L	Jan 28/05
Queen St. Sample Station	Nitrate	9.6	mg/L	Feb 1/05
Carroll/Parkview Sample	Nitrate	9.5	mg/L	Feb 1/05
184 Parkview	Nitrate	9.5	mg/L	Feb 1/05
York St. Well #13	Nitrate	10.3	mg/L	Feb 28/05
York St. Blended (8,9,13)	Nitrate	10.3	mg/L	Feb 28/05
S.P. Carroll/Parkview	Nitrate	10.2	mg/L	Feb 28/05
S.P. Carroll/Queen	Nitrate	10.3	mg/L	Feb 28/05
18 Calvin St.	Nitrate	10.3	mg/L	Mar 18/05
390 York St.	Nitrate	10.3	mg/L	Mar 18/05
62 Parkview Cr.	Nitrate	10.3	mg/L	Mar 18/05
187 Parkview Drive	Nitrate	10.3	mg/L	Mar 18/05
S.P. Carroll/Parkview	Nitrate	10.2	mg/L	Mar 18/05
S.P. Carroll/Queen	Nitrate	10.3	mg/L	Mar 18/05
91 Egerton	Nitrate	10.3	mg/L	Mar 18/05
351 Frances St.	Nitrate	9.09	mg/L	Mar 18/05
351 Frances St.	Nitrate	8.0	mg/L	Mar 26/05
168 Metcalfe St.	Nitrate	5.33	mg/L	Mar 26/05
75 Caradoc St.	Nitrate	6.38	mg/L	Mar 26/05
Gemini Sportsplex	Nitrate	7.25	mg/L	Mar 26/05
S.P. Carrie/Hospital	Nitrate	5.73	mg/L	Mar 26/05
TW Well #8	Nitrate	9.34	mg/L	Mar 26/05
TW Well #9	Nitrate	9.08	mg/L	Mar 26/05
TW Well # 8/9 Combined	Nitrate	9.07	mg/L	Mar 26/05
TDW SP Carroll/Parkview	Nitrate	10.1	mg/L	Mar 30/05
91 Egerton	Nitrate	6.68	mg/L	Mar 30/05
75 Caradoc St.	Nitrate	6.45	mg/L	Mar 30/05
3230 Napperton Dr.	Nitrate	5.27	mg/L	Mar 30/05
Gemini Sportsplex	Nitrate	7.80	mg/L	Mar 30/05
Reservoir Inlet	Nitrate	5.35	mg/L	Mar 30/05
TDW Well #8	Nitrate	10.1	mg/L	Mar 30/05
TDW Well #9	Nitrate	10.5	mg/L	Mar 30/05
TDW Well 8/9 Blend	Nitrate	10.5	mg/L	Mar 30/05

188 Parkview Dr.	Nitrate	9.91	mg/L	Mar 30/05
TDW 390 York Downhams	Nitrate	9.78	mg/L	Apr 12/05
S.P. Carroll/Parkview	Nitrate	9.83	mg/L	Apr 12/05
390 York St. Downhams	Nitrate	9.49	mg/L	Jul 13/05
S.P. Carroll/Parkview	Nitrate	9.41	mg/L	Jul 13/05
390 York St. Downhams	Nitrate	5.40	mg/L	Aug 16/05
S.P. Carroll/Parkview	Nitrate	9.50	mg/L	Aug 16/05
S.P. Carroll/Parkview	Nitrate	8.78	mg/L	Sep 20/05
390 York St. Downhams	Nitrate	10.4	mg/L	Oct 14/05
S.P. Carroll/Parkview	Nitrate	10.5	mg/L	Oct 14/05
390 York St. Downhams	Nitrate	6.18	mg/L	Nov 17/05
S.P. Carroll/Parkview	Nitrate	9.79	mg/L	Dec 8/05
3230 Napperton	Nitrate	6.59	mg/L	Dec 22/05
263 Pine Tree	Nitrate	6.09	mg/L	Dec 22/05
47 Parkview	Nitrate	7.03	mg/L	Dec 22/05
351 Frances St.	Nitrate	6.84	mg/L	Dec 22/05
390 York St./Downhams	Nitrate	7.81	mg/L	Dec 22/05
S.P. Carroll @ Parkview	Nitrate	7.31	mg/L	Dec 22/05

Summary of Inorganic parameters (Nitrite) tested during this reporting period or most recent

Site	Sample Date	Result Value	Unit of Measure	Exceedance
York St. Well #13	Feb 28/05	0.005<MDL	mg/L	No
York St. Blended (8,9,13)	Feb 28/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Feb 28/05	0.005<MDL	mg/L	No
S.P. Carroll/Queen	Feb 28/05	0.005<MDL	mg/L	No
18 Calvin St.	Mar 18/05	0.005<MDL	mg/L	No
390 York St.	Mar 18/05	0.005<MDL	mg/L	No
62 Parkview Cr.	Mar 18/05	0.005<MDL	mg/L	No
187 Parkview Drive	Mar 18/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Mar 18/05	0.005<MDL	mg/L	No
S.P. Carroll/Queen	Mar 18/05	0.005<MDL	mg/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

91 Egerton	Mar 18/05	0.005<MDL	mg/L	No
351 Frances St.	Mar 18/05	0.005<MDL	mg/L	No
18 Calvin Ct	Mar 26/05	0.005<MDL	mg/L	No
62 Parkview Cr.	Mar 26/05	0.005<MDL	mg/L	No
184 Parkview Dr.	Mar 26/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Mar 26/05	0.005<MDL	mg/L	No
S.P. Carroll/Queen	Mar 26/05	0.005<MDL	mg/L	No
91 Egerton St.	Mar 26/05	0.005<MDL	mg/L	No
351 Frances St.	Mar 26/05	0.005<MDL	mg/L	No
168 Metcalfe St.	Mar 26/05	0.005<MDL	mg/L	No
127 Queen St.	Mar 26/05	0.005<MDL	mg/L	No
352 High St.	Mar 26/05	0.005<MDL	mg/L	No
75 Caradoc St.	Mar 26/05	0.005<MDL	mg/L	No
3230 Napperton	Mar 26/05	0.005<MDL	mg/L	No
Gemini Sportsplex	Mar 26/05	0.005<MDL	mg/L	No
Middlesex Memorial Arena	Mar 26/05	0.005<MDL	mg/L	No
S.P. Carrie/Hospital	Mar 26/05	0.005<MDL	mg/L	No
TW Well #8	Mar 26/05	0.005<MDL	mg/L	No
TW Well #9	Mar 26/05	0.005<MDL	mg/L	No
TW Well # 8/9 Combined	Mar 26/05	0.005<MDL	mg/L	No
TW Bosquart Well 11B	Mar 29/05	0.005<MDL	mg/L	No
TW Bosquart Well 11D	Mar 29/05	0.005<MDL	mg/L	No
TDW SP Carroll/Parkview	Mar 30/05	0.005<MDL	mg/L	No
91 Egerton	Mar 30/05	0.005<MDL	mg/L	No
351 Frances	Mar 30/05	0.005<MDL	mg/L	No
168 Metcalfe St.	Mar 30/05	0.005<MDL	mg/L	No
127 Queen St.	Mar 30/05	0.005<MDL	mg/L	No
352 High St.	Mar 30/05	0.005<MDL	mg/L	No
75 Caradoc St.	Mar 30/05	0.005<MDL	mg/L	No
3230 Napperton Dr.	Mar 30/05	0.005<MDL	mg/L	No
Gemini Sportsplex	Mar 30/05	0.005<MDL	mg/L	No
Middlesex Memorial Arena	Mar 30/05	0.005<MDL	mg/L	No
S.P. Carrie/Hospital	Mar 30/05	0.005<MDL	mg/L	No
Reservoir Inlet	Mar 30/05	0.005<MDL	mg/L	No
TDW Well #8	Mar 30/05	0.005<MDL	mg/L	No
TDW Well #9	Mar 30/05	0.005<MDL	mg/L	No
TDW Well 8/9 Blend	Mar 30/05	0.005<MDL	mg/L	No
390 York Downhams	Mar 30/05	0.005<MDL	mg/L	No
62 Parkview Cr.	Mar 30/05	0.005<MDL	mg/L	No
188 Parkview Dr.	Mar 30/05	0.005<MDL	mg/L	No
S.P. Carroll/Queen	Mar 30/05	0.005<MDL	mg/L	No
TDW 390 York	Apr 12/05	0.005<MDL	mg/L	No

Downhams				
S.P. Carroll/Parkview	Apr 12/05	0.005<MDL	mg/L	No
390 York St. Downhams	May 16/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	May 16/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Jun 14/05	0.005<MDL	mg/L	No
390 York St. Downhams	Jun 14/05	0.005<MDL	mg/L	No
390 York St. Downhams	Jul 13/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Jul 13/05	0.005<MDL	mg/L	No
390 York St. Downhams	Aug 16/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Aug 16/05	0.005<MDL	mg/L	No
390 York St. Downhams	Sep 20/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Sep 20/05	0.005<MDL	mg/L	No
390 York St. Downhams	Oct 14/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Oct 14/05	0.005<MDL	mg/L	No
390 York St. Downhams	Nov 17/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Nov 17/05	0.005<MDL	mg/L	No
390 York St. Downhams	Dec 8/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Dec 8/05	0.005<MDL	mg/L	No
3230 Napperton	Dec 22/05	0.005<MDL	mg/L	No
263 Pine Tree	Dec 22/05	0.005<MDL	mg/L	No
47 Parkview	Dec 22/05	0.005<MDL	mg/L	No
351 Frances St.	Dec 22/05	0.005<MDL	mg/L	No
390 Yorke St. Downhams	Dec 22/05	0.005<MDL	mg/L	No
S.P. Carroll/Parkview	Dec 22/05	0.005<MDL	mg/L	No

Site	Sample Date	Result Value	Unit of Measure	Exceedance

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)